CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION OFFICE OF THE STATE FIRE MARSHAL

FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7320-0065:134 Page 1 of 1

CATEGORY: Speakers

LISTEE: Faraday Inc., 805 S. Maumee St., Tecumseh MI 49286

Contact: Steven A. Blohm (517) 423-2111

DESIGN: Models 2623, 2624, 2625 speakers; Models 2626, 2627 and 2628 speaker strobes with suffix-

N (15cd), -W (15cd), -D (75cd) or -S (110cd). Refer to listee's data sheet for additional detailed

product description and operational considerations.

RATING: 25 V rms and 70 V rms

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and

in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name or registered trademark "FOS", model number, electrical rating and UL label.

APPROVAL: Listed as speakers and speaker strobe for use with separately listed electrically compatible fire

alarm control units. Models with strobe are suitable for the hearing impaired application. For

indoor use only.

If this appliance is required to produce a distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1993 Edition, the appliance must be used with a fire alarm control unit that can generate the temporal pattern

signal. Refer to manufacturer's Installation Manual for details.

*Corrected 07-29-96



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

FEBRUARY 21, 2001 Date Issued: Listing Expires June 30, 2002

A uthorized By: **BEN HO**, Supervising Deputy

Program Manager